

KVALITETSIKRING / KONTROLPLAN

Nødlysanlegg

☐ Utførelse og driftsettelse av nyanlegg ☐ Endring av anlegg ☒ Årskontroll iflg. Kontrakt ☐ Kontroll etter reparasjon.

Kunde / Tiltakshaver: Indre Fosen Kommune
 Anleggssted: Omsorgsboliger Bergeekra
 Adresse: Bergeekra 17, 7100 Rissa
 G.nr: B.nr: Tiltaksklasse: Brannklasse: Risikoklasse:
 Krav (forskr. /regelv.): NEK EN 50172
 Sentraltype:

*Sentralisert system: ☐	J = ja N = Nei	Armatur	Er armaturen testet?	Har armaturen rett piktogram?	Batteritype:	Er lysrør skiftet?	Er armaturen tilpasset leseavstand? (se utregningsformel.)	Er armaturen i orden -uten skade?	Har armaturen min. 1 t. backup?	Kurs /skap:
Armaturtype: (LL/ML)	Formel for utregning av skiltstørrelse og leseavstand: $p = d/200(S)$ $p =$ piktogramhøyde $d =$ leseavstand $S = 200$ (gjennomlyste skilt)									
Wattstyrke:										
Tilkobl. 24V:(1)										
Tilkobl.230V:(2)										
Armaturplassering										

Fordeling 2.etg:										
LL- 2 LED	Ventilasjonsrom 2.etg	✓	✓			LED		✓	✓	XF05
ML- 2 LED	Ventilasjonsrom 2.etg	✓	✓	J		LED	J	✓	✓	XF05
LL- 2 LED	Ved brannslange 2.etg	✓	✓			LED		✓	✓	XF05
ML- 2 LED	Ved brannslange 2.etg	✓	✓	J		LED	J	✓	✓	XF05
ML- 2 LED	Over dør. Topp trapp 2.etg	✓	✓	J		LED	J	✓	✓	XF02
ML- 2 LED	Rom utenfor hovedtavle 2.etg	✓	✓	J		LED	J	✓	✓	XF01
LL- 2 LED	Rom utenfor hovedtavle 2.etg	✓	✓			LED		✓	✓	XF01
LL- 2 LED	Ved hovedtavle 2.etg	✓	✓			LED		✓	✓	XF01
LL- 2 LED	Topp trapp 2.etg	✓	✓			LED		✓	✓	XF05
Fordeling rom 138 1.etg										
ML- 2 LED	Over dør til 2.etg	✓	✓	J		LED	J	✓	✓	XF03
LL- 2 LED	Utvendig. Rømningsrød fellesrom	✓	✓			LED		✓	✓	XF02
ML- 2 LED	Rømningsrød fellesrom	✓	✓	J		LED	J	✓	✓	XF02
LL- 2 LED	Fellesrom	✓	✓			LED		✓	✓	XF02
ML- 2 LED	Gang ved sprinklerrom	✓	✓	J		LED	J	✓	✓	XF02
LL- 2 LED	Gang ved rom 140	✓	✓			LED		✓	✓	XF02
LL- 2 LED	I rom 136	✓	✓			LED		✓	✓	XF03
LL- 2 LED	Ved brannsentral	✓	✓			LED		✓	✓	XF02
ML- 2 LED	Gang utenfor vaktrom	✓	✓	J		LED	J	✓	✓	XF02
LL- 2 LED	Vaktrom	✓	✓			LED		✓	✓	XF01
ML- 2 LED	Vaktrom	✓	✓	J		LED	J	✓	✓	XF01
LL- 2 LED	Utvendig. Dør inn til vaktrom	✓	✓			LED		✓	✓	XF01

Kommentarer: Klikk her for å skrive inn tekst.

Ordre nr: Saksbehandler: Service ing. Sign.: *Sanja Albrecht* Dato: 17. nov. 20
 Tegnings nr: Sluttkontroll sign.: Dato:
 Kundens representant: