




Sentralisert: Nei Forsyning: 230V 	Formel for leseavstand: $L = Z \times H$ Z = 200 for gjennomlyste skilt 			Testet / Kontrollert : 			Generelt: Det installerte anlegget er kontrollert, feil/avvik er utbedret ref. oversikt.
Armaturtype	Armaturplassering:	UF - Kurs nr.	NL ID	1 Time Backup	Armaturen er fysisk i orden, uten ladefeil.	Armaturen tilpasset lese avstand	
Kommentar / Avvik							
Oppgang nr.6							
ML -- LED	Over Ytterdør VF	432.01-F64	A-03	OK	OK	OK	
ML -- LED	Gang ved VF	432.01-F64	A-04	Nei	Nei	OK	Defekt, fungerer ikke
LL -- LED	Trapp til kjeller	432.01-F64	A-40	OK	OK		
LL -- LED	Trapperom kjeller	432.01-F64	A-37	OK	OK		
LL -- LED	Repo plan 1	432.01-F64	A-41	Nei	OK		Holder ikke 60-min
LL -- LED	Gang plan 1	432.01-F64	A-02	OK	OK		
LL -- LED	Kjøkken plan 1	433.101-F3	A-01	OK	OK		
LL -- LED	Trapp til plan 2	432.01-F64	A-18	OK	OK		
LL -- LED	Repo plan 2	432.01-F64	A-19	OK	OK		
LL -- LED	Gang plan 2	432.01-F64	A-17	OK	OK		
LL -- LED	Kjøkken plan 2	433.102-F3	A-05	Nei	Nei		Defekt, fungerer ikke
Oppgang nr.5							
ML -- LED	Over Ytterdør VF	432.01-F63	A-10	OK	OK	OK	
ML -- LED	Gang ved VF	432.01-F63	A-09	OK	OK	OK	
LL -- LED	Trapp til kjeller	432.01-F63	A-43	OK	OK		
LL -- LED	Trapperom kjeller	432.01-F63	A-39	OK	OK		
LL -- LED	Repo plan 1	432.01-F63	A-08	OK	OK		
LL -- LED	Gang plan 1	432.01-F63	A-07	OK	OK		
LL -- LED	Kjøkken plan 1	433.201-F3	A-06	OK	OK		
LL -- LED	Trapp til plan 2	432.01-F63	A-22	OK	OK		
LL -- LED	Repo plan 2	432.01-F63	A-23	OK	OK		
LL -- LED	Gang plan 2	432.01-F63	A-21	OK	OK		
LL -- LED	Kjøkken plan 2	433.202-F3	A-20	OK	OK		
Oppgang nr.4							
ML -- LED	Over Ytterdør VF	432.01-F62	A-14	Nei	OK	OK	Holder ikke 60-min
ML -- LED	Gang ved VF	432.01-F62	A-13	OK	OK	OK	
LL -- LED	Trapp til kjeller	432.01-F62	A-42	OK	OK		
LL -- LED	Trapperom kjeller	432.01-F62	A-38	OK	OK		
LL -- LED	Repo plan 1	432.01-F62	A-44	OK	OK		
LL -- LED	Gang plan 1	432.01-F62	A-12	OK	OK		
LL -- LED	Kjøkken plan 1	433.301-F3	A-11	OK	OK		
LL -- LED	Trapp til plan 2	432.01-F62	A-26	OK	OK		
LL -- LED	Repo plan 2	432.01-F62	A-27	Nei	OK		Holder ikke 60-min
LL -- LED	Gang plan 2	432.01-F62	A-25	OK	OK		
LL -- LED	Kjøkken plan 2	433.302-F3	A-24	OK	OK		
Kjeller							
ML -- LED	Mot oppgang 6	432.01-52	A-36	OK	OK	OK	
LL -- LED	Kjellergang	432.01-52	A-35	OK	OK		
LL -- LED	Kjellergang	432.01-52	A-34	OK	OK		
LL -- LED	Kjellergang	432.01-52	A-33	OK	OK		
ML -- LED	Mot oppgang 5	432.01-52	A-32	OK	OK	OK	
LL -- LED	Kjellergang	432.01-52	A-31	OK	OK		
LL -- LED	Kjellergang	432.01-52	A-30	OK	OK		
ML -- LED	Mot oppgang 4	432.01-52	A-29	OK	OK	OK	
LL -- LED	Kjellergang	432.01-52	A-28	OK	OK		

[illegible]