


AUTORISERT EINSTALLATÖR

Centralisert:	Formel for leseavstand: $L = Z \times H$ $Z = 200$ for gjennomlyste skilt			Testet / Kontrollert :			Generelt: Det installerte anlegget er kontrollert, feil/avvik er utbedret ref. oversikt.
Nei				1 Time Backup	Armaturen er fysisk i orden, uten ladefeil.	Armaturen tilpasset lese avstand	
Forsyning:							
230V							
Armaturtype	Armaturplassering:	UF - Kurs nr.	NL ID				Kommentar / Avvik
	Oppgang nr.3						
ML -- LED	Over Ytterdør VF	433.01-F56	D-23	OK	OK	OK	
ML -- LED	Gang ved VF	433.01-F56	D-22	OK	OK	OK	
LL -- LED	Trapp til kjeller	433.01-F56	D-49	OK	OK		
LL -- LED	Trapperom kjeller	433.01-F56	D-50	OK	OK		
LL -- LED	Repo plan 1	433.01-F56	D-21	OK	OK		
LL -- LED	Gang plan 1	433.01-F56	D-20	OK	OK		
LL -- LED	Kjøkken plan 1	433.301-F3	D-19	OK	OK		
LL -- LED	Trapp til plan 2	433.01-F56	D-33	OK	OK		
LL -- LED	Repo plan 2	433.01-F56	D-32	OK	OK		
LL -- LED	Gang plan 2	433.01-F56	D-34	OK	OK		
LL -- LED	Kjøkken plan 2	433.302-F12	D-35	OK	OK		
	Oppgang nr.2						
ML -- LED	Over Ytterdør VF	433.01-F55	D-18	Nei	OK	OK	Holder ikke 1 time
ML -- LED	Gang ved VF	433.01-F55	D-17	OK	OK	OK	
LL -- LED	Trapp til kjeller	433.01-F55	D-47	OK	OK		
LL -- LED	Trapperom kjeller	433.01-F55	D-48	OK	OK		
LL -- LED	Repo plan 1	433.01-F55	D-16	OK	OK		
LL -- LED	Gang plan 1	433.01-F55	D-15	OK	OK		
LL -- LED	Kjøkken plan 1	433.201-F12	D-14	OK	Nei		Viser ladefeil, (Lyser ved utkobl.)
LL -- LED	Trapp til plan 2	433.01-F55	D-29	OK	OK		
LL -- LED	Repo plan 2	433.01-F55	D-28	OK	OK		
LL -- LED	Gang plan 2	433.01-F55	D-30	OK	OK		
LL -- LED	Kjøkken plan 2	433.202-F12	D-31	OK	OK		
	Oppgang nr.1						
ML -- LED	Over Ytterdør VF	433.01-F54	D-12	OK	OK	OK	
ML -- LED	Gang ved VF	433.01-F54	D-11	OK	OK	OK	
LL -- LED	Trapp til kjeller	433.01-F54	D-36	OK	OK		
LL -- LED	Trapperom kjeller	433.01-F54	D-37	OK	OK		
LL -- LED	Repo plan 1	433.01-F54	D-10	OK	OK		
LL -- LED	Gang plan 1	433.01-F54	D-09	OK	OK		
LL -- LED	Kjøkken plan 1	433.101-F3	D-08	OK	OK		
LL -- LED	Trapp til plan 2	433.01-F54	D-25	OK	OK		
LL -- LED	Repo plan 2	433.01-F54	D-24	OK	OK		
LL -- LED	Gang plan 2	433.01-F54	D-26	OK	OK		
LL -- LED	Kjøkken plan 2	433.102-F3	D-27	OK	OK		
	Kjeller						
ML -- LED	Mot oppgang 3	432.001-F45	D-46	OK	OK	OK	
LL -- LED	Kjellergang	432.001-F45	D-45	OK	OK		
LL -- LED	Kjellergang	432.001-F45	D-44	OK	OK		
LL -- LED	Kjellergang	432.001-F45	D-43	OK	OK		
ML -- LED	Mot oppgang 2	432.001-F45	D-42	Nei	OK	OK	Holder ikke 1 time
LL -- LED	Kjellergang	432.001-F45	D-41	OK	OK		
LL -- LED	Kjellergang	432.001-F46	D-40	OK	OK		
LL -- LED	Kjellergang	432.001-F46	D-39	OK	OK		
ML -- LED	Mot oppgang 1	432.001-F46	D-38	Nei	OK	OK	Holder ikke 1 time

[illegible]